



NOTIFIED BODY 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0179

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Steel rectangular single compartment smoke control duct, TOP-KOD 120

designed to transport smoke and/or hot gases away from the source of fire and for the control of pressurising and excess air relief within pressurisation systems; used on conditions defined in the Assessment and verification of constancy of performance No. C1396/19/0026/4004/SC issued by FIRES, s.r.o., Notified Body 1396 on 09. 06. 2020,

placed on the market under the name or trade mark of

**TOPEKO HVAC & FIRESTOP SYSTEMS d.o.o.
Šejkina 54b/30, 11160 Beograd, Serbia**

and produced in the manufacturing plant(s)

**TOPEKO HVAC & FIRESTOP SYSTEMS d.o.o.
Šejkina 54b/30, 11160 Beograd, Serbia**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 12101-7: 2011

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 09. 06. 2020 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce 09. 06. 2020

117168

FIRES 136a/C-31/01/2017-E



Ing. Henrieta Lapková
Head of Product Certification Body